

CEST CNC FREZE DEKORASYON  
MOBİLYA İNŞAAT VE DIŞ TİCARET  
LİMİTED ŞİRKETİ.

Merkez Mah. 714 Sk. No:11a, Bağcılar, İstanbul  
/ TURKIYE

Our reference EEA-2500-0099  
Project number EEA-25-001308-REV1

Dilovası, 02 October 2025

## Confirmation of test results

To whom it may concern,

On 01.10.2025 Efectis Era Avrasya performed a test in accordance with EN 1634-1:2014+A1:2018 on Single Leaf Timber Door “CD-WD01 Cest Dizayn Wooden Fire Door” on behalf of CEST CNC FREZE DEKORASYON MOBİLYA İNŞAAT VE DIŞ TİCARET LİMİTED ŞİRKETİ.

A first analysis of the measurement data and observations resulted in the following preliminary results:

Direction of fire	Opening into the fire
Performance criterion	Time [min]
Integrity (E)	42
Insulation (I)	38

These results are only valid for the tested “construction / material”. The final “test / classification” report will contain a full description of the field of application which applies to the results.

Whilst the test information and results provided within this confirmation were obtained from a test conducted fully in accordance with EN 1634-1:2014+A1:2018 the presentation of the results in this manner does not satisfy the requirements of that standard and ISO 17025:2017. Additionally, according to quality assurance, the results are informative until the completion of the full final “test / classification” report.

The information provided in this confirmation and in consistency with EGA 039 agreement is valid for six months only or until the full “test / classification” report is issued, whichever comes first.

Kind regards,

*e-signed*

Ali BAYRAKTAR  
Laboratory Manager